


General description

The access doors for rectangular ducting (FAD-HT) and for round ducting (CAD-HT) consist of two panels connected between themselves with two screws, springs and knobs.

Thanks to the fitted ceramic gasket and the steel knobs, they will resist high temperatures up to 200°C (will meet 400°C /2H certification).

Access doors allow easy admittance to the ventilation ducting for the purpose of inspection and cleaning.




Technical specification

PANELS	Material	Galvanized steel
SEALING GASKET	Type	High quality ceramic gasket
	Dimension	4 mm x 18 mm
	Density	+/- 160 Kg / m ³
	Temperature range	- 30°C / + 1500 °C
COMPONENTS COMPRESSION SYSTEM	Screws	2 screws: M8x40 or M10x40 crimped on internal panel
	Springs	2 compressions springs
	Knobs	2 steel knobs with metal insert M8 or M10

Self-adhesive template comes with each door, for accurate cut-out

Sizes

Door type	Nominal sizes (mm)	Actual sizes (mm) The format is oblong, and the radius of the 4 angles is equivalent to the small size divided by 2.			
		A	B	C	D
18	180 x 80	170	72	197	101
20	200 x 100	200	100	219	117
25	250 x 150	250	150	274	186
30	300 x 200	300	200	329	228
42	400 x 200	380	180	412	212
40	400 x 300	380	280	403	303
50	500 x 400	500	400	532	432
60	600 x 450	600	450	627	480




A & B = opening dimensions
C & D = external dimensions

CAD selection chart for round ducting

Door size Duct dia.	180x80 mm	200x100 mm	250x150 mm	300x200 mm	400x300 mm	500x400 mm	600x450 mm	Recommended door curving diameter (mm)
100 mm	Standard	-	+	-	-	-	-	100
125 mm	Standard	-	+	-	-	-	-	125
140 mm	+	Standard	+	-	-	-	-	
150 mm	+	+	+	-	-	-	-	
160 mm	Standard	+	Standard	-	-	-	-	160
180 mm	+	Standard	+	-	-	-	-	200
200 mm	Standard	Standard	Standard	-	-	-	-	
224 mm	+	+	+	-	-	-	-	
250 mm	+	Standard	Standard	-	-	-	-	250
280 mm	+	+	+	-	-	-	-	
300 mm	+	+	+	-	-	-	-	
315 mm	-	Standard	Standard	Standard	-	-	-	315
355 mm	-	-	Standard	Standard	-	-	-	355
400 mm	-	-	Standard	Standard	Standard	-	-	400
450 mm	-	-	Standard	Standard	Standard	-	-	450
500 mm	-	-	Standard	Standard	Standard	-	-	500
550 mm	-	-	-	+	+	-	-	560
560 mm	-	-	-	+	Standard	-	-	
600 mm	-	-	-	+	+	-	-	
630 mm	-	-	-	+	Standard	Standard	-	630
700 mm	-	-	-	-	+	+	-	710
710 mm	-	-	-	-	Standard	Standard	Standard	
800 mm	-	-	-	-	Standard	Standard	Standard	
850 mm	-	-	-	-	+	+	+	900
900 mm	-	-	-	-	Standard	Standard	Standard	
1000 mm	-	-	-	-	+	Standard	Standard	
1120 mm	-	-	-	-	+	Standard	Standard	1120
1250 mm	-	-	-	-	+	Standard	Standard	1250
1400 mm	-	-	-	-	-	-	+	
1500 mm	-	-	-	-	-	-	+	
1600 mm	-	-	-	-	-	-	Standard	
1800 mm	-	-	-	-	-	-	Standard	

+ : Available on request
- : Not available





Recommendations (based on EN 12097)


Access door needs to be fitted :

- before and after every fitting (dampers, fire dampers, filters, duct fans, duct heaters,...)
- after more than one change of direction of more than 45° as from the access door
- after more than one change of airflow as from the access door
- at least every 7,5 m


ROUND DUCTING (CAD)		RECTANGULAR DUCTING (FAD)	
Nominal duct diameter (mm)	Minimal size of access door (mm) A x B	Width of duct where access door is fitted (mm) S	Minimal size of access door (mm) A x B
$100 \leq D < 200$	180 x 80	$S \leq 200$	180 x 80
$200 \leq D \leq 315$	250 x 150	$200 < S \leq 400$	300 x 200
$315 < D \leq 500$	300 x 200	$400 < S \leq 500$	400 x 300
$500 < D$	400 x 300	$500 < S$	500 x 400




Application




1. Stick self-adhesive template on to duct (a template is provided with each door)



2. Using Turbo Shears or similar cut around template taking care not to exceed the size of the template (the door will function correctly when cut to template size +0 mm -3 mm).



3. Install door by unscrewing the hand knobs until thread is level with top of bolt. Using both hands place the door in the hole at an angle.



4. Turn straight and pull out slightly to align. Then tighten knobs.

Information contained herein is based on careful tests and experience. It reflects our knowledge and is for guidance purpose only. It is given in good faith and user should ensure that the product is fit for purpose before any application. The quoted values are average and should not be taken as maximum or minimum values for specific purposes. Manufacturer and distributor are not responsible for any non-recommended use or consequential damage.